

4" Square LED Downlight Installation Instructions

- ♦ WARNING Risk of fire or electric shock. LED Retrofit Kit installation requires knowledge of luminaires electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician.
- ♦ WARNING Risk of fire or electric shock. Install this kit only in luminaires that have the construction features and dimensions shown in the photographs and/or drawings and where the input rating of the retrofit kit does not exceed the input rating of the luminaire.
- ◆ Do not make or alter any open holes in an enclosure of wiring or electrical components during kit installation
- ◆ WARNING To prevent wiring damage or abrasion, do not expose wiring to edges of sheet metal or other sharp objects
- ♦ Supply conductors (power wires) connecting the fixture must be rated minimum 90°C. If uncertain, consult an electrician.
- ◆ Risk of Electric Shock: Disconnect power or circuit breaker before installing or servicing.
- ◆NOTE: This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:


This device may not cause harmful interference, and

This device must accept any interference received, including interference that may cause undesired operation.

- ♦ WARNING Risk of fire or electric shock. The electrical rating of these products are 120 Vac, the installer must determine whether they have 100-120 Vac at the luminaire before installation.
- ◆ Compatible with most LUTRON & LEVITON Dimmer.
- ♦ RISK OF ELECTRIC SHOCK USE IN DRY AND DAMP LOCATION
- ♦ THIS DEVICE IS NOT INTENDED FOR USE WITH EMERGENCY EXITS
- ◆ This kind of light is adjustable light, can be applied to the commonly used dimmer and dimmer range is in 10% ~ 100%
- ◆ The light comes with a connector for California Title 24 Compliance, and is UL Listed.

Electrical parameters:

Model No.	Input voltage (VAC)	Input current (Ampere)	Input wattage(Watts)
4610-XX-SQ	120	0.083A	10



Disconnect power before installation

STEP1: Twist adaptor into socket. STEP2: Insert male connector into female one. STEP3: Push in the can





